

# Annexure C

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 31

Dated: 16/05/2025

It is certified that an inspection team headed by Dr. Amit (M.O.) (Name of Officers with designation) from Primary Health Centre, inspected the **Nityanand Vidya Niketan, Lakhana, Etawah** (Name & Address of the school) on **16/05/2025** (date of inspection) and on the basis of Water Test Report (Attached) bearing no **TC-12223-2500000031F** dated **13/05/2025** of **District Level Water Analysis Laboratory of Uttar Pradesh Jal Nigam(Rural) Etawah** certified that the **Nityanand Vidya Niketan, Lakhana, Etawah** has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 1 year from issue date

Signature with Seal: .....

Name: Dr. Amit .....

Designation: M.O. .....

Name & Address of the Office / Department : CHC. Blwana.

*All*  
चिकित्सा अधिकारी  
सामुहिक स्वास्थ्य केन्द्र  
लखना-इटावा

To

**Nityanand Vidya Niketan,  
Lakhana, Etawah**



# District Level Water Analysis Laboratory of Uttar Pradesh Jal Nigam (Rural) Etawah



TC-12223

## Analysis Water Test Report

ULR No.	TC-12223-250000031F	Chemical Test/31	Date: 13/05/2025	Page No.	1
<b>Customer Details</b>					
Office Name & Address	Nityanand Vidya Niketan Manpura Road Lakhana Etawah				
Ref. Letter No. & Date	00 - (08/05/2025)				
<b>Basic Details of Sample</b>					
District	Etawah	Block	Mahewa		
Gram Panchayat	Lakhana Dehat	Village	Lakhana Dehat		
Habitation	Lakhana Dehat	Location	Kali Mandir		
Water Source	Submersible	Sample code & Lab code	ETW/25/05/1P & 1071P		
Quantity of Sample	2 Liter	Date of S.C	08/05/2025		
Receiving Date	08/05/2025	S. Collector	Arun Kumar Pandey		
Sample Depositor	Arun Kumar Pandey	Analysis Completion Date	13/05/2025		
Analysis Start Date	09/05/2025				
<b>Environmental Condition</b>					
Temperature	25±3°C	Humidity	50±15%		
<b>Technical Data of Analysis</b>					
S. No.	Analyzed Parameters	Observed Value	Specified Values as per BIS 10500:2012		Ref. Method of Analysis
			Acceptable Limit	Permissible	
1	Odour	Agreeable	Agreeable	Agreeable/Not Agreeable	IS3025(Part 5): 2023
2	Taste	Agreeable	Agreeable	Agreeable/Not Agreeable	IS3025 (Part 7): 2023
3	Colour	5	5	15	IS3025(Part-4):2021
4	Turbidity (NTU)	1.32	1	5	IS3025(Part-10):2023 (Nephelometric method)
5	pH	7.95	6.5	8.5	IS3025(Part11):2022 (Electrometric Method)
6	TDS (Mg/L)	382	500	2000	IS3025 (Part 16 ):2023 (Gravimetric Method)
7	Alkalinity (Mg/L)	160	200	600	IS3025(Part-23):2023 (indicator Method)
8	Total Hardness (Mg/L)	260	200	600	IS3025(Part-21):2019 (EDTA)
9	Sulphate (Mg/L)	52.75	200	400	IS3025(Part-24):2022
10	Nitrate (Mg/L)	38.87	45	No Relaxation	APHA Method 24 <sup>rd</sup> Addition 4500 : 2023
11	Iron (Mg/L)	0.33	0.3	1.0	IS3025 (Part-53) : 2024(1,10 Phenanthroline Method)
12	Chloride (Mg/L)	50	250	1000	IS3025)Part-32):2019
13	Magnesium (Mg/L)	50.51	30	100	IS3025(Part-46):2023
14	Calcium (Mg/L)	52.10	75	200	IS3025(Part-40):2023
15	Fluoride (Mg/L)	0.50	1.0	1.5	IS3025 (Part-60):2008 (Electro Chemical Prob. Method)
<p>Note:-</p> <p>1- This Certificate refers only to the particular sample (s) submitted for testing.</p> <p>2- This Certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory</p> <p>3- The test result reported in this certificate are valid at the time of and under the stated conditions of measurements.</p> <p>4- Sample will be stored up to 7 days (in case of non-perishable items only) from the date of issue of test reports unless otherwise specified.</p> <p>5- Parameters above permissible limit are written in Bold.</p>					
 <p>Report Prepared By DQM/DTM Pradeep Kumar</p>			 <p>Authorized Signatory (Shivam Kumar Verma) Quality Manger/Technical Manager</p>		
Laboratory Contact Details Email-etawahlab@gmail.com					
Mob-8126544535					

End of Report



## District Level Water Analysis Laboratory of Uttar Pradesh Jal Nigam (Rural) Etawah.

Issue No. : 03

Issue Date-13/05/2025


Report /Sample Code/Lab Code	Bacteria Test/ ETW/25/05/B/1P (1071P)	District	Etawah
Office Name & Address	Nityanand Vidya Niketan Manpura Road Lakhana Etawah	Block	Mahewa
Gram Panchayat	Lakhana Dehat	Village	Lakhana Dehat
Habitation	Lakhana Dehat	Location	Kali Mandir
Water Source	Submersible	Sample No	1
Quantity of Sample	2 Litre	Date Of Collection	08/05/2025
Receiving Date	08/05/2025	Sample Collector	Arun Kumar Pandey
Sample Depositor	Arun Kumar Pandey	Sampling Method	-
Analysis Start Date	09/05/2025	Analysis Completion	13/05/2025
Temperature	25±3°C	Humidity	50±15%

### Technical Data Of Analysis

Sr.No.	Analysed Parameter	Observed Value	Specified Values as Per BIS 10500:2012		Ref. Method of analysis
			Acceptable Limit	Permissible Limit	
1.	pH	7.95	6.5-8.5	No relaxation	IS 3025(Part-11 )2022
2.	Residual Chlorine (Mg/L)	0.2	0.20	1.00	IS 3025(Part-26 )2022
3.	Total Coliform (CFU)	0.0	No relaxation	No relaxation	IS 15185:2016
4.	E .Coli (CFU)	0.0	No relaxation	No relaxation	IS 15185:2016

NOTE:

1. This certificate refers only to the particular sample submitted for testing.
2. This certificate shall not be reproduced, except in full unless written permission of an approved has been Obtained from Head of Laboratory.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample Will be Stored up to 07 days (in case of non.-perishable items only) from the date of issue.



(Tested & Checked By)



Shivam Kumar Verma  
Quality Manager / Technical Manager  
Approved By

End of Report